

FI 4974-01-2-C1

FIRE TEST SUMMARY CERTIFICATE



This is to certify that the specimen described below was tested by BRANZ in accordance with AS ISO 9705:2003 (R2016) and ISO 9705:1993.

Test Sponsor

Autex Industries Ltd
702-718 Rosebank Road
Rosebank
Auckland, 1348
New Zealand

Date of Test

21 August 2012

Reference BRANZ Test Report

FI4974-01-2 – issued 18/06/2024

Test Specimen as described by the Sponsor

The Autex Quietspace Cube specimen was stated by the client as 2400 gsm at 12 mm 200 kg/m³ polyester. The client stated that this product is alternatively branded Autex Quietspace Workstation, or Autex Quietspace Nude.

Determination of Fire Hazard Properties

The specimen was deemed suitable for testing in accordance with AS 5637.1:2015, and the testing was performed in accordance with AS ISO 9705:2003 (R2016) to determine the Group Number classification as specified in the NCC Volume One. The test comprised three walls and the ceiling lined with the test specimen.


Classification in Accordance with NCC Australia and New Zealand Building Code

Calculations were carried out in accordance with AS 5637.1:2015 and NZBC Verification Method C/VM2 Appendix A. The Group Number classification and SMOGRARC for the sample, as described above, are provided in the table below.

Regulatory authorities are advised to examine test reports before approving any product.

Building Code Document	Classification
NZBC Verification Method C/VM2 Appendix A	Group Number 1-S The average smoke production rate was 0.7 m ² /s and therefore not greater than the 5.0 m ² /s limit
NCC Volume One Specification 7, Clause S7C4 determined in accordance with AS 5637.1:2015	Group 1 The SMOGRARC was 1.4 m ² /s ² x 1000 and therefore within the 100 m ² /s ² x 1000 limit

Issued by


L. Q. Greive
Associate Fire Testing Engineer
BRANZ

Issue Date

18/06/2024

Reviewed and approved for release by


L. F. Hersche
Fire Testing Engineer
IANZ Approved Signatory



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation