# AVEVAWORLD

PARIS

INTERNAL

# **16<sup>TH</sup> OCTOBER 2024**



# MINIMIZING EQUIPMENT DOWNTIME AND UNDER PERFORMANCE Issues through data monitoring on a centralized solar power plant using aveva pi system

Gustavo Onofre, Gonçalo Fontenele





# Gugl

AVEVA

About Company and Presenters
Asset Overview and Distribution
Overview and Background
Solution Development

**Conclusion and Results** 

# About Company and Presenters





#### **Gustavo Onofre**

Head of Operational Excellence Enel Green Power Solar Brazil gustavo.onofre@enel.com

# **FADIX**



#### **Gonçalo Fontenele**

Industrial Data Analyst Radix goncalo.junior@radixeng.com



# Asset Overview and Distribution



\*Under construction (TBC in 2024).



**Total Installed Capacity: 1,8 GW** 













\*Under construction (TBC in 2024).

#### Size Comparison



Solar Cluster total area: ~18km<sup>2</sup>





Transmission Line →46.1 km



PV Module & Tracker  $\rightarrow$  4.461.694 un  $\rightarrow$  77.930 un



Transformer LV/MV →411 un



Stringbox →4.826 un

**MV Feeder** 

→631 km



Inverters →3.930 un



Transformer MV/HV  $\rightarrow 8$  un





# **Overview and Background**

#### BACKGROUND

**ENEL** Solar Brazil has a PI System installed with an asset hierarchy well defined since the beginning of the project. Although used for multiple activities, even for eventframe generation, plants were not standardized on events and displays;

**All 7 plants** have their own particularities, needed to be considered on PI System;

**Also**, was acknowledged an opportunity to improve and accelerate the development of automatic classification on going;

**Field** team used to verify inverters' alarms on Plant SCADA, acting only in equipment interruption events, but not in inefficiencies;

**Culture** mindset change from manual and operational work to analytical and strategic for all O&M team (field and back office).



#### OVERVIEW OF THE CHALLENGE AND SOLUTION





**Standardizing** the identification of failures and underperformance in inverters, currently relying on a time-consuming manual process that results in substantial losses and highlights the need for an automated system to monitor key performance indicators and enhance operational efficiency.



**Deployed** the latest AVEVA PI System technology including PI AF and PI Vision as an advanced foundation for Process Monitoring, Failure Identification and Bad Performance Issues Reduction.



**Benefits** 

**Increased** production and operational efficiency, reduced costs, reduced time-consuming inspections, faster data visualization of all plants and inefficiency events identification, post-operational automatic classification of inefficiencies.



# OVERVIEW OF THE CHALLENGE AND SOLUTION




#### Asset Hierarchy on PI Asset Framework

All plants have the same structure of eventframe
generation and analysis, when possible. Also, the same PI
Vision displays are available, considering each power plant
particularity;



We will showcase mostly São Gonçalo Solar Complex (867,26 MWp)

## **OVERVIEW OF THE CHALLENGE AND SOLUTION**




**120K** 

Monthly average of failure /

inefficiency events

Loss Production events, associated with the failure or inneficiency of one or a combination of elements that participate in the generation system:

**10K** 



Number of core tags

\*Solar Plant example

São Gonçalo example:

• 19 Sub-plants;

Daily number of 500K measures processed

enel radix


**Power Plants** 


# Solution Development

#### **Project** Workflow



**Using** consolidated business rules and merging it with expected power of inverters, so that inefficiencies and failures could be identified and classified







#### **Eventframe** Generation;

**15-20** Eventframe types, mostly on inverter level, with failure or bad performance indication;

**Flags** created for data-driven verifications on post-operational analysis, including automatic classification of inefficiencies, using enumeration set for reason and root cause identification.



+3.5k

Most Critical Equipment




85k Elements Directly Covered





**Using** consolidated business rules and merging it with expected power of inverters, so that inefficiencies and failures could be identified and classified





#### **FASTER DATA VISUALIZATION**

Uses **data** that already exists on PI AF on **displays**, mostly **inverter** data.



#### **EVENTFRAME VISUALIZATION**

Strategic view of **events table**, with different severities, showing all the events that causes loss of production.

#### MAIN EQUIPAMENT STATUS

Show equipment **failure** and its **unavailability** according to business rule.


#### **COMMUNICATION ERRORS**

Show communication error in all plant levels (feeder, inverter, stringbox...).

#### **REAL AND PRODUCIBLE COMPARISON**

Direct comparison between irradiance, as producible in **MW**, with **actual active power** in **MW**.


#### Top Management Display




#### **Executive Plant** Display

Planta	Chel 🦙 0&M Solar Brasil   ITUVERAVA - VISÃO GERENCIAL							Help Solar
161,25 MW       160,06 MW       163,70 MW       196,00 MW       196,00 MW       Independences       Indep				Circuitos	Inversorer	Stringhover	Trackers	
Circuitos       Inversores       Stingboxes       Trackers       Inversores en fabla de comm fabla de comm de monitoramento       Stingbox con fabla de monitoramento         - 0 / 14       - 0 / 98       13 / 1274       - 0 / 19600       - 0 / 98       - 0 / 1274         Inversores en de monitoramento         - 0 / 14       - 0 / 98       - 0 / 1800       - 0 / 182       - 0 / 182       - 0 / 2800       23,24 mw / 22,68 mw         Inversores en de monitoramento         Nome do evenito         Sever v Nome do evenito         Fabla de Equipamento - Stingbox associada so inversor         Inversor Singbox associada so invers	■ 161,25 MW ■ 160,06 MW ■ 163,70 MW ■ 196,00 MW					indisponíveis		Potência Ativa / Produzível
Circuitos       Inversores       Stringboxes       Trackers       Indisponíveis       Trackers       Indisponíveis       Indi	Ad	Manora I	ITV 01	- 0/2	- 0 / 14	- 0 / 182	- 0 / 2800	22,91 мw / 23,47 мw
Eventos en Andamento         Seve y Nome do evento       Alivo Tempo inicial Duração Reconhecimento Reconhecido por Inversor de B.12 - 00/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 0006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 25006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 27006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 27006/2024         Importante       Faha de Equipamento - Stringbox associada ao Inversor 04.8.12 - 27006/2024         Inversor 04.8.12 - 27006/2024		Stringbox com falha	ITV 02	- 0/2	- 0 / 14	<b>0</b> / 182	- 0 / 2800	 23,24 мw / 22,68 мw
Seve v       Nome do evento       Ativo       Tempo inicial       Duração       Reconhecimento       Reconhecido por         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       10/06/2024       17 d 6 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       10/06/2024       16 d 20 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       10/06/2024       16 d 20 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       25/06/2024       2d 6 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       25/06/2024       2d 6 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       27/06/2024       6 h 41 m       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       27/06/2024       6 h 41 m       Reconhecer         Secundário       Inversor AlB.12 - 27/06/2024       6 h 41 m       Reconhecer       IIV 07       - 0 / 14       - 0 / 182       - 0 / 2800       21,56 MW / 23,81 MW         Secundário       Inversor Alixo e Alarme de Aviso - Código:       Inversor <td>- 0 / 14 - 0 / 98 - 13 / 1274 - 0 / 19600 - 0 / 98</td> <td></td> <td>ITV 03</td> <td>- 0/2</td> <td>- 0 / 14</td> <td>- 0 / 182</td> <td>- 0 / 2800</td> <td>23,04 мw / 23,17 мw</td>	- 0 / 14 - 0 / 98 - 13 / 1274 - 0 / 19600 - 0 / 98		ITV 03	- 0/2	- 0 / 14	- 0 / 182	- 0 / 2800	23,04 мw / 23,17 мw
Importante       Inversor 04.B.12 - 10/06/2024       04.B.12       06:36:00       17 d b n       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       10/06/2024       16 d 20 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       10/06/2024       16 d 20 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       23,40 MW / 23,17 MW         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       26 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       27/06/2024       6 h 41 m       Reconhecer         Secundário       Inversor Alizo e Alarme de Aviso - Código:       Inversor       10/06/2024       16 h 41 m       Reconhecer         Inversor Alizo e Alarme de Aviso - Código:       Inversor       10/06/2024       16 h 41 m       Reconhecer         Inversor Alizo e Alarme de Aviso - Código:       Inversor       10/06/2024       16 h 41 m       Reconhecer         Inversor Alizo e Alarme de Aviso - Código:       Inversor       10/06/2024       16 h 41 m       Reconhecer         Inversor Alizo e Alarme de Aviso - Código:       Inversor       10/06/2024       16 h 41 m			ITV 04	- 0/2	- 0 / 14	- 13 / 182	- 0 / 2800	23,57 мw / 23,62 мw
Importante       Inversor 03.8.10 - 10006/2024       03.8.10       10:43:00         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       25/06/2024       2 d 6 h       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       04.8.12       06/40:00       6 h 41 m       Reconhecer         Secundário       Inversor 04.8.12 - 27/06/2024       06.40:00       6 h 41 m       Reconhecer         Importante       Falha de Equipamento - Stringbox associada ao       Inversor       04.8.12       06/40:00       6 h 41 m       Reconhecer         Secundário       Inversor 04.8.12 - 27/06/2024       06.40:00       16 d 20 h       Reconhecer       111 V 07       - 0 / 14       - 0 / 182       - 0 / 2800       23,53 MW / 23,81 MW	Importante Inversor 04.B.12 - 10/06/2024 04.B.12 06:36:00 17.4 0 n Recontrecer		ITV 05	- 0/2	- 0 / 14	- 0 / 182	- 0 / 2800	23,40 мw / 23,17 мw
Importante         Falha de Equipamento - Stringbox associada ao         Inversor         27/08/2024         6 h 41 m         Reconhecer           Secundário         Inversor Alixo e Alarme de Aviso - Código: Fan         Inversor         10/05/2024         16 d 20 h         Reconhecer           Inversor Alixo e Alarme de Aviso - Código:         Inversor         10/05/2024         16 d 20 h         Reconhecer	Inversor 03.B.10 - 10/06/2024 03.B.10 16:43:00							
Secondario fault interior - 10/08/2024 03A.05 17:19:30 10 8.20 n Reconnecter	Importante         Falha de Equipamento - Stringbox associada ao Inversor 04.B.12 - 27/06/2024         Inversor 04.B.12         27/06/2024 06:40:00         8 h 41 m         Reconhecer		ITV 06	- 072	- 0 / 14	- 0 / 182	- 0 / 2800	21,56 мw 7 23,78 мw
Inversor Ativo e Alarme de Aviso - Codigo: Inversor 10/06/2024 do Loon	fault interior - 10/08/2024 03.A.05 17:19:30 10 0 20 n			- 0/2	- 0 / 14	- 0 / 182	- 0 / 2800	23.53 MW / 23.81 MW
	Secundário Inversor Ativo e Alarme de Aviso - Código: Inversor 10/08/2024 16 d 20 h Reconhecer Warning insulation failure - 10/08/2024 01.A.04 17:19:30 16 d 20 h			- 072	- 0714	- 0 7 102	- 0 72000	20,00 MW 7 20,01 MW


#### Subpark Level Display



#### **Inverter Level** Display




**Using** consolidated business rules and merging it with expected power of inverters, so that inefficiencies and failures could be identified and classified






#### **POST-OPERATIONAL CLASSIFICATION**

#### Data Flow in PI System



## POST-OPERATIONAL CLASSIFICATION

**Global** System Integration





# **Conclusion and Results**



#### **Project Drivers**



**Real Time** Monitoring, Analysis and Intelligent Alarms



Failure Identification and Inefficiency Classification



Faster Data Visualization and Event Acknowledgement



Data-Driven Field Operations and Maintenance



**Reduction** of Manual Load focusing on strategic activities

기근! 🏠 0&M Solar Brasil   ITUVERAVA - VISÃO GERENCIAL					Help Solar
Planta 🔮 P.A. alimentadores: Potência produzível: Potência setpoint 1421 75 anu: 4 don do anu: 4 don 20 anu:	Subparques	Circuitos Inversores	Stringboxes	Trackers	Potência Ativa / Produzível
161,25 MW 160,06 MW 163,70 MW 196,00 MW		indisponívels indisponívels	indisponíveis — 0 / 182	indisponíveis - 0 / 2800	22,91 mw / 23,47 mw
Cinuitos Investores Stingboxes Traskers Investores em násponíveis indisponíveis falta de comm	Stringbox com falha de monitoramento	- 0 / 2 - 0 / 14	y 0 / 182	- 0 / 2800	23,24 mw / 22,68 mw
- 0 / 14 - 0 / 98 - 13 / 1274 - 0 / 19600 - 0 / 98	- 0 / 1274	- 0 / 2 - 0 / 14	- 0 / 182	- 0 / 2800	23,04 mw / 23,17 mw
Eventos em Andamento Seve <b>v</b> Nome do evento Alivo Tempo inicial Duração Reconhecimento	Reconhecido por	- 0 / 2 - 0 / 14	- 13 / 182	- 0 / 2800	23,57 мw / 23,62 мw
Falha de Equipamento - Stringbox associada ao Inversor 10/06/2024					
Insortant         Insortant         Insortant         International Control (Control (Contro) (Control (Control (Contro) (Control (Control (Co	ITV 05	- 0 / 2 - 0 / 14	- 0 / 182	- 0 / 2800	23,40 MW / 23,17 MW
Inportante Inversor 04.B.12 - 1006/2024 04.B.12 08:38:00 17 0 0 Reconnecer	ITV 05	- 0 / 2 - 0 / 14 - 0 / 2 - 0 / 14	- 0 / 182 - 0 / 182	- 0 / 2800 - 0 / 2800	23,40 mw / 23,17 mw 21,56 mw / 23,78 mw



# ✓ Real Time Monitoring, Analysis and Intelligent Alarms

O Executive and operational displays showing real time plant condition and alarms.

# **Faster Data Visualization and Event Acknowledgement**

O Events displayed colored by priority category and enabling acknowledgement by field operator.

# **Data-Driven Field Operations and Maintenance**


O First steps of data driven analysis enabling future improvements to anticipate failures and avoid losses.

# Reduction of Manual Load focusing on strategic activities

O No need for manual input from field or back office team. mindset change for analytical and strategic work.



#### **Inefficiency** Detection and Suggested Root Cause



Ineficiências Constatadas				
Nome do evento	Tempo inicial	Tempo final	Duração	Motivo
menciencia Constatada - Inversor UTA.U3 - U8/U8/24 - 11.UU - 14.10	08/08/2024 11:00:00	08/08/2024 14:10:00	3111011	Curtailment
Ineficiência Constatada - Inversor 01.A.03 - 09/09/24 - 07:45 - 11:00	09/09/2024 07:45:00	09/09/2024 11:00:00	3 h 15 m	Grid Limitation - Ancillary Services
Ineficiência Constatada - Inversor 01.A.03 - 09/09/24 - 07:00 - 07:15	09/09/2024 07:00:00	09/09/2024 07:15:00	15 m	Current Inefficiency - Zone Monitoring
Ineficiência Constatada - Inversor 01.A.03 - 09/09/24 - 08:45 - 07:00	09/09/2024 06:45:00	09/09/2024 07:00:00	15 m	Tracker Failure

# Failure Identification and Inefficiency Classification


O Automatic events with suggested failures and inefficiency root cause acquired by algorithms created with O&M know-how.

O Automatic classification in post-operational reports without the need for human intervention.

#### 

#### **Events** of Loss Of Production Automatically Classified on São Gonçalo Complex

# Percentage of Events Automatically Classified in São Gonçalo 1



Up to **93%** of automatic classification on loss of production in Aug/24 on SGL1;

Also, up to **91%** of automatic classification on loss of production in Aug/24 on other plants;

#### **Expected Results:**

Reduction of losses due to real time inefficiency alarms identification in PI Vision Displays;

Reduced man-power costs by providing main cause of failures, optimizing time during field inspections and corrective maintenance;

All the hours once focused on manual classification of events converted in analysis and "decision-making" work time, grants a much faster and effective response upon new failures and inefficiencies;



Estimated around 5 GWh of yearly losses avoided in São Gonçalo Cluster due to faster event identification (**i.e. equivalent to 1 day extra of full Generation**);



**5 GWh extra production represents avoiding, approximately, 341ton of CO2 emissions** (equivalent reduction of 2.0M km traffic by economic combustion engine cars per year or equally the equivalent of reforesting around 61.000 trees during the remainder of the plant's life cycle). "With the new system of automatic classification and realtime display of events, I have more time to focus on detailed analysis. It surely helps me making the right decision to maintain the best operation of the plant." - Plant Manager



## Project Roadmap

#### **Current Scenario (2024)**

PI Vision Real Time Monitoring and Failure Identification; Post-Operation Automatic Classification.



#### Future Goal

Maximize Solar Operation Efficiency; Data Driven algorithms to achieve predictive maintenance complete solution using Al.

#### Past Scenario

Unknown financial losses due to difficulties in managing large volumes of data and technical failures; Absence of a standard Monitoring System; Workforce waste and overload for manual inefficiency classification.





#### Project Start (2023)

PI System AF Standardizing; PI tags for automatic classification algorithms; PI Vision Monitoring System.





#### POWER | BRAZIL

# Enel Green Power minimizes equipment downtime and improves performance

#### Challenge

- Standardizing the identification of failures and underperformance in inverters
- Currently relying on a time-consuming manual process that results in substantial losses and highlights the need for an automated system to monitor key performance indicators and enhance operational efficiency.

#### **Solution**

• Deployed the latest AVEVA PI System technology including PI AF and PI Vision as an advanced foundation for Process Monitoring, Failure Identification and Bad Performance Issues Reduction.

#### Results

- Estimated around 5 GWh of yearly losses avoided in São Gonçalo Cluster due to faster event identification
- Increased production and operational efficiency
- Reduced costs, reduced time-consuming inspections
- Faster data visualization of all plants and inefficiency events identification, postoperational automatic classification of inefficiencies.



# Thank You!





Gustavo Onofre Head of Operational Excellence EGP Brazil gustavo.onofre@enel.com CADIX

Gonçalo Fontenele Industrial Data Analyst Radix goncalo.junior@radixeng.com



This presentation may include predictions, estimates, intentions, beliefs and other statements that are or may be construed as being forward-looking. While these forward-looking statements represent our current judgment on what the future holds, they are subject to risks and uncertainties that could result in actual outcomes differing materially from those projected in these statements. No statement contained herein constitutes a commitment by AVEVA to perform any particular action or to deliver any particular product or product features. Readers are cautioned not to place undue reliance on these forward-looking statements, which reflect our opinions only as of the date of this presentation.

The Company shall not be obliged to disclose any revision to these forward-looking statements to reflect events or circumstances occurring after the date on which they are made or to reflect the occurrence of future events.



#### ABOUT AVEVA

AVEVA is a world leader in industrial software, providing engineering and operational solutions across multiple industries, including oil and gas, chemical, pharmaceutical, power and utilities, marine, renewables, and food and beverage. Our agnostic and open architecture helps organizations design, build, operate, maintain and optimize the complete lifecycle of complex industrial assets, from production plants and offshore platforms to manufactured consumer goods.

Over 20,000 enterprises in over 100 countries rely on AVEVA to help them deliver life's essentials: safe and reliable energy, food, medicines, infrastructure and more. By connecting people with trusted information and AI-enriched insights, AVEVA enables teams to engineer efficiently and optimize operations, driving growth and sustainability.

Named as one of the world's most innovative companies, AVEVA supports customers with open solutions and the expertise of more than 6,400 employees, 5,000 partners and 5,700 certified developers. The company is headquartered in Cambridge, UK.

Learn more at www.aveva.com