PRELIMINARY WALL SECTIONS - GRAVITY

The following sections for gravity Novum Wall retaining walls are based on idealized and assumed conditions and are intended for reference and preliminary planning purposed only. They are NOT intended for use or as replacement for site-specific Novum Wall retaining wall design. Seismic, flood, rapid drawdown, toe slopes, and any other loading condition not described have not been evaluated or included in the preliminary wall sections. Final project designs, including all construction details, internal and external stability, and drainage, shall be prepared by a <u>licensed professional engineer</u> using the actual conditional of the proposed site.



PRELIMINARY WALL SECTIONS - GRAVITY

The following sections for gravity Novum Wall retaining walls are based on idealized and assumed conditions and are intended for reference and preliminary planning purposed only. They are NOT intended for use or as replacement for site-specific Novum Wall retaining wall design. Seismic, flood, rapid drawdown, toe slopes, and any other loading condition not described have not been evaluated or included in the preliminary wall sections. Final project designs, including all construction details, internal and external stability, and drainage, shall be prepared by a <u>licensed professional engineer</u> using the actual conditional of the proposed site.

SOIL TYPE - SITLY SAND or FINE to MEDIUM SAND ($\phi = 30^{\circ}$)

LOAD CONDITION - NO LIVE LOAD SURCHARGE. LOAD CONDITION - 100 psf (4.8 kPa) LIVE LOAD SURCHARGE, NO CREST SLOPE, NO TOE SLOPE NO CREST SLOPE, NO TOE SLOPE NOTE: SURCHARGE APPLIES TO LIGHT VEHICULAR OR PEDESTRIAN LOADING CONDITIONS. 100 psf (4.5 kPa) LIVE LOAD SURCHARGE $\phi = 30^{\circ}$ 5 ft 6 in (1.68 m) 6 ft 0 in φ = 30^o EXPOSED (1.83 m) HEIGHT DESIGNED 4 ft 0 in 4 ft 6 in DRAINAGE STONE (1.22 m) HEIGHT (1.37 m) DESIGNED DRAINAGE STONE EXPOSED HEIGH⁻ 1H:1V MIN SAFE HEIGHT EXCAVATION* 1H:1V MIN SAFE EXCAVATION* DRAINAGE PIPE DRAINAGE PIPE EMBEDMENT DEPTH EMBEDMENT DEPTH CRUSHED STONE LEVELING PAD CRUSHED STONE LEVELING PAD 6 in (150 mm) 6 in (150 mm) 6 in (150 mm) 6 in (150 mm) MAXIMUM GRAVITY HEIGHT = 6 ft 0 in (1.83 m) MAXIMUM GRAVITY HEIGHT = 4 ft 6 in (1.37 m) LOAD CONDITION - 250 psf (12 kPa) LIVE LOAD LOAD CONDITION - NO LIVE LOAD SURCHARGE, SURCHARGE, NO CREST SLOPE, NO TOE SLOPE 2.5H:1V CREST SLOPE, NO TOE SLOPE NOTE: SURCHARGE APPLIES TO ROADWAY OR PARKING LOT LOADING CONDITIONS. φ = 30° 1 ft 6 in 1 ft 0 in 4 ft 0 in 4 ft 6 in DRAINAGE STONE (0.46 m)(0.31 m)(1.22 m)250 psf (12 kPa) LIVE LOAD SURCHARGE DESIGNED EXPOSED (1.37 m) EXPOSED DESIGNED HEIGHT HEIGHT HEIGHT HEIGHT 1H:1V MIN SAFE EXCAVATION* φ = 30 1H:1V MIN SAFE DRAINAGE PIPE EXCAVATION* DRAINAGE STONE EMBEDMENT DEPTH EMBEDMENT DEPTH CRUSHED STONE LEVELING PAD CRUSHED STONE LEVELING PAD 6 in (150 mm) 6 in (150 mm) 6 in (150 mm) DRAINAGE PIPE 6 in (150 mm) MAXIMUM GRAVITY HEIGHT = 1 ft 6 in (0.46 m) MAXIMUM GRAVITY HEIGHT = 4 ft 6 in (1.37 m)

PRELIMINARY WALL SECTIONS - GRAVITY

The following sections for gravity Novum Wall retaining walls are based on idealized and assumed conditions and are intended for reference and preliminary planning purposed only. They are NOT intended for use or as replacement for site-specific Novum Wall retaining wall design. Seismic, flood, rapid drawdown, toe slopes, and any other loading condition not described have not been evaluated or included in the preliminary wall sections. Final project designs, including all construction details, internal and external stability, and drainage, shall be prepared by a <u>licensed professional engineer</u> using the actual conditional of the proposed site.

SOIL TYPE - DENSE WELL GRADED SAND or SAND and GRAVEL (ϕ = 34°)

LOAD CONDITION - NO LIVE LOAD SURCHARGE, NO CREST SLOPE, NO TOE SLOPE LOAD CONDITION - 100 psf (4.8 kPa) LIVE LOAD SURCHARGE, NO CREST SLOPE, NO TOE SLOPE NOTE: SURCHARGE APPLIES TO LIGHT VEHICULAR OR PEDESTRIAN LOADING CONDITIONS.



MAXIMUM GRAVITY HEIGHT = 3 ft 0 in (0.91 m)

MAXIMUM GRAVITY HEIGHT = 5 ft 3 in (1.60 m)

PRELIMINARY WALL SECTIONS - GRAVITY

The following sections for gravity Novum Wall retaining walls are based on idealized and assumed conditions and are intended for reference and preliminary planning purposed only. They are NOT intended for use or as replacement for site-specific Novum Wall retaining wall design. Seismic, flood, rapid drawdown, toe slopes, and any other loading condition not described have not been evaluated or included in the preliminary wall sections. Final project designs, including all construction details, internal and external stability, and drainage, shall be prepared by a <u>licensed professional engineer</u> using the actual conditional of the proposed site.

SOIL TYPE - CRUSHED STONE BACKFILL REPLACING SILTY or CLAYEY SAND (\$\$\phi\$ = 40° over 26°)

LOAD CONDITION - NO LIVE LOAD SURCHARGE, NO CREST SLOPE, NO TOE SLOPE LOAD CONDITION - 100 psf (4.8 kPa) LIVE LOAD SURCHARGE, NO CREST SLOPE, NO TOE SLOPE NOTE: SURCHARGE APPLIES TO LIGHT VEHICULAR OR PEDESTRIAN LOADING CONDITIONS.

100 psf (4.5 kPa) LIVE LOAD SURCHARGE



MAXIMUM GRAVITY HEIGHT = 6 ft 0 in (1.83 m)



MAXIMUM GRAVITY HEIGHT = 5 ft 3 in (1.60 m)

LOAD CONDITION - 250 psf (12 kPa) LIVE LOAD SURCHARGE, NO CREST SLOPE, NO TOE SLOPE NOTE: SURCHARGE APPLIES TO ROADWAY OR PARKING LOT LOADING CONDITIONS.

LOAD CONDITION - NO LIVE LOAD SURCHARGE, 2.5H:1V CREST SLOPE, NO TOE SLOPE



PRELIMINARY WALL SECTIONS - GRAVITY

The following sections for gravity Novum Wall retaining walls are based on idealized and assumed conditions and are intended for reference and preliminary planning purposed only. They are NOT intended for use or as replacement for site-specific Novum Wall retaining wall design. Seismic, flood, rapid drawdown, toe slopes, and any other loading condition not described have not been evaluated or included in the preliminary wall sections. Final project designs, including all construction details, internal and external stability, and drainage, shall be prepared by a licensed professional engineer using the actual conditional of the proposed site.

EXAMPLE CALCULATIONS

The following pages represent an example background calculation that the preliminary wall sections for gravity Novum Wall retaining walls were based upon. The sample calculation evaluates the first preliminary wall section displayed on page 1 of this document. The soil type is SILTY SAND or CLAYEY SAND ($\phi = 28^\circ$) and the load condition is NO LIVE LOAD SURCHARGE, NO CREST SLOPE, NO TOE SLOPE.

The preliminary calculations were completed using National Concrete Masonry Association (NCMA) program SRWall (Version 4) and the designs are in general accordance with *NCMA Design Manual for Segmental Retaining Walls, 3rd Edition.* The analysis considers Novum Wall retaining blocks with standard batter of 5.2° for average block sizes and weights.

The preliminary design minimum factor of safety is 1.5 for sliding and overturning, and 2.0 for bearing capacity. Overall slope (global) stability has NOT been checked and is required to be evaluated for every wall section shown for final design. Seismic, flood, rapid drawdown, toe slopes, and any other loading condition not described in the preliminary wall sections have not been evaluated. If a project exhibits any of those loading scenarios, these preliminary wall sections do not apply.

All other preliminary wall section calculations are available upon request. Please reach out to the Redi-Rock Engineering Team at 866-222-8400, option 2 or engineering@redi-rock.com to request additional preliminary background calculations.

		LOAD CONDITION			
SOIL TYPE		NO LIVE LOAD SURCHARGE, NO CREST SLOPE, NO TOE SLOPE	100 psf (4.8 kPa) LIVE LOAD, NO CREST SLOPE, NO TOE SLOPE	250 psf (12 kPa) LIVE LOAD, NO CREST SLOPE, NO TOE SLOPE	NO LIVE LOAD SURCHARGE, 2.5H:1V CREST SLOPE, NO TOE SLOPE
	MAX.	5.25 ft (1.60 m)	3.75 ft (1.14 m)	N/A	3.75 ft (1.14 m)
SILTY SAND or CLAYEY SAND $(\phi = 28^{\circ})$	EMBED	0.5 ft (150 mm)	0.5 ft (150 mm)	N/A	0.5 ft (150 mm)
	BASE	0.5 ft <i>(150 mm)</i>	0.5 ft <i>(150 mm)</i>	N/A	0.5 ft <i>(150 mm)</i>
SILTY SAND or FINE to MEDIUM SAND (\$\overline{4} = 30^{\overline{0}})	MAX.	6.0 ft (1.83 m)	4.5 ft (1.37 m)	1.5 ft (0.46 m)	4.5 ft (1.37 m)
	EMBED	0.5 ft (150 mm)	0.5 ft (150 mm)	0.5 ft (150 mm)	0.5 ft (150 mm)
	BASE	0.5 ft (150 mm)	0.5 ft (150 mm)	0.5 ft (150 mm)	0.5 ft <i>(150 mm)</i>
DENSE WELL-GRADED SAND	MAX.	6.0 ft (1.83 m)	6.0 ft (1.83 m)	3.0 ft (0.91 m)	5.25 ft (1.60 m)
or SAND and GRAVEL $(\phi = 34^\circ)$	EMBED	0.5 ft (150 mm)	0.5 ft (150 mm)	0.5 ft (150 mm)	0.5 ft (150 mm)
	BASE	0.5 ft (150 mm)	0.5 ft <i>(150 mm)</i>	0.5 ft (150 mm)	0.5 ft <i>(150 mm)</i>
CRUSHED STONE BACKFILL REPLACING SILTY or CLAYEY SAND (ϕ = 40° over 26°)	MAX.	6.0 ft (1.83 m)	5.25 ft (1.60 m)	4.5 ft (1.37 m)	4.5 ft (1.37 m)
	EMBED	0.5 ft (150 mm)	0.5 ft (150 mm)	0.5 ft (150 mm)	0.5 ft (150 mm)
	BASE	0.5 ft (150 mm)	0.5 ft <i>(150 mm)</i>	0.5 ft (150 mm)	0.5 ft (150 mm)

SRWall (Version 4) Report

Project Identification

:
: Novum Wall Preliminary Wall Sections
: Redi-Rock
:
: LBH
: Redi-Rock International
: 2940 Parkview Drive, Petoskey, MI 49770
: 231-489-7800
: H=5.25 ft / 28-deg soil / No surcharge, no backslope, no toe slope
: NW_A_28_NR_5.25_calcs.prj
:
: 01/16/2024 16:54:30

Type of Structure

: Gravity Wall

Wall Geometry

Design Wall Height(ft)	: 5.25
Embedment Wall Height(ft)	: 0.50
Exposed Wall Design Height(ft)	: 4.75
Number of Segmental Wall Units	: 7
Wall Inclination(degrees)	: 5.14

<u>Grades</u>

Top Slope(degrees) : 0.00

Uniform Distributed Surcharge

Live Load Surcharge(Psf)	: 0.00
Dead Load Surcharge(Psf)	: 0.00

Soil Data

Soil Zone	Description	Cohesion (c) (psf)	Friction Angle(Φ) (degrees)	Unit Weight (γ)(pcf)
Retained Soil	Silty sand, clayey sand	N/A	28.00	120.00
Leveling Pad Soil	Crushed stone	N/A	40.00	130.00
Foundation Soil	Silty sand, clayey sand	0.00	28.00	120.00

Segmental Unit Data

: Novum Wall Retaining Block
: 0.00
: 9.00
: 24.00
: 46.12
: 0.81
: 684.00
: 118.65
: 11.70

Unit-Unit Interface Properties

Minimum Shear	Shear Friction	Maximum Shear
Capacity(lb/ft)	Angle	Capacity (lb/ft)
1479.00	71.00	4291.00

Vertical Components

Vertical Components of Earth Pressures Used : Yes

Cofficients of Earth Pressure and Failure Plane Orientation

Retained Soil(Static)(Ka)	: 0.286
Retained Soil(Static)(Kah Horizontal Component)	: 0.264
External Modified Back Slope(Bext)	: 0.000
Orientation of failure plane from horizontal(degrees) for External Stability	: 52.854

Result of External Stability Static Analysis

	Calculated	Design Criteria
FOS Sliding	1.73	> 1.50
FOS Overturning	2.12	> 1.50
FOS Bearing Capacity	2.82	> 2.00
Base Footing (B)(ft)	2.50	

Results of Internal Stability Static Analysis

SRW Unit #	Heel Elev (ft)	FOS Shear >=1.50
7	4.50	212.71
6	3.75	66.95
5	3.00	35.87
4	2.25	23.62
3	1.50	17.32
2	0.75	12.70

Project Identification

Project ID	:
Project Name	: Novum Wall Preliminary Wall Sections
Owner	: Redi-Rock
Client	:
Prepared By	: LBH
Company	: Redi-Rock International
Address	: 2940 Parkview Drive, Petoskey, MI 49770
Telephone	: 231-489-7800
Section	: H=5.25 ft / 28-deg soil / No surcharge, no backslope, no toe slope
Vendor Data File	:
Project File	: NW_A_28_NR_5.25_calcs.prj
Date and Time	: 01/16/2024 16:54:30
